TECHNICAL INFORMATION Standard Cast Pipeline Strainers

Pressure Drop Calculations

Pressure drops for Eaton strainers are shown on each product page. The curves are based on the flow of water through clean, perforated baskets or screens. For mesh-lined baskets or screens and/or for fluids other than water, use the correction factors listed on this page. To accurately calculate the pressure loss for filters and strainers in a pipeline, proceed as follows:

- 1. First calculate pressure loss using C_V factor formula at right.
- 2. Take the pressure loss figure obtained in (1) and recalculate it using the appropriate correction factor from the following table.

Correction Factors for Mesh-lined Baskets

First - Multiply the pressure drop for water shown in charts by the specific gravity of the liquid.

Second – Multiply the corrected pressure drop figure by the following correction factors for more viscous liquids. (Water has a viscosity of 30 SSU.)

Viscosity (SSU)	Unlined Perforated Basket	40 Mesh Lined Basket	60 Mesh Lined Basket	80 Mesh Lined Basket	100 Mesh Lined Basket	200 Mesh Lined Basket	325 Mesh Lined Basket
30 (water)	1	1.2	1.4	1.6	1.7	2.0	2.5
500	1.6	1.9	2.1	2.4	2.6	3.1	3.6
1000	1.7	2.2	2.4	2.6	2.8	3.3	3.8
2000	1.9	2.4	2.7	2.9	3.2	3.8	4.0
3000	2.0	2.6	2.9	3.2	3.5	4.1	4.3
5000	2.2	3.0	3.5	4.0	4.5	5.3	6.3
10000	2.5	3.5	4.2	5.0	6.0	7.1	8.5

Strainer Basket Opening Equivalents

Mesh	Inches	Millimeters	Microns	Perf	Inches	Millimeters	Microns			
400	0.0015	0.0381	38	1/32	0.033	0.838	838			
300	0.0018	0.0457	45	3/64	0.045	1.143	1143			
250	0.0024	0.0609	60	1/16	0.070	1.778	1776			
200	0.0027	0.0686	68	3/32	0.094	2.387	2387			
150	0.0041	0.1041	104	1/8	0.125	3.175	3175			
100	0.0065	0.1651	165	5/32	0.150	3.810	3810			
80	0.007	0.1778	177	3/16	0.1875	4.762	4762			
60	0.009	0.2286	228	1/4	0.250	6.350	6350			
40	0.015	0.8636	380	3/8	0.375	9.525	9525			
20	0.034	0.8636	862	1/2	0.500	12.700	12700			

Pressure Loss Calculation Using C_V Factor

Metric Units

$$\Delta P = \left[\frac{Q}{C_v}\right]^2 (133.6)$$

 ΔP = Pressure Drop in kPa

 $Q = Flow in M^3/hr$

C_V = Flow Coefficient

Standard Units

$$\Delta P = \left[\frac{Q}{C_V}\right]^2$$

 ΔP = Pressure Drop in psi

Q = Flow in qpm

C_V = Flow Coefficient

The pressure loss across a strainer can be calculated using the system's flow rate and the C_V factor for that strainer.

For example, a 1" Model 72 simplex strainer with a perforated basket has a C_V factor of 22.5. In water service with a 30 gpm flow rate, it will have a 1.7 psi pressure drop $(30 \div 22.5)^2 = 1.7$. For mesh-lined baskets and/or fluids with a viscosity greater than water, multiply the pressure drop by the correction factors in the chart "Correction Factors for Mesh-lined Baskets."

Eaton North America - HQ

44 Apple Street, Tinton Falls, NJ 07724

Toll Free: 800 656-3344 (North America only)

Voice: +1 732 212-4700 Fax: 952 906-3706

Eaton Brazil

Voice: +55 11 2465 8822

Eaton China

Voice: +86-21 5200 0422

Europe/Africa/Middle East

Voice: +49-2486-809-0

Eaton Singapore

Voice: +65 6825 1668

©2013 Eaton Corporation. All Rights Reserved. All trademarks and registered trademarks are the property of their respective owners. Litho USA. All information and recommendations appearing in this brochure concerning the use of products described herein are based on tests believed to be reliable. However, it is the user's responsibility to determine the suitability for his own use of such products. Since the actual use by others is beyond our control, no guarantee, expressed or implied, is made by Eaton as to the effects of such use or the results to be obtained. Eaton assumes no liability arising out of the use by others of such products. Nor is the information herein to be construed as absolutely complete, since additional information may be necessary or desirable when particular or exceptional conditions or circumstances exist or because of applicable laws or

For more information, e-mail us at filtration@eaton.com

Visit us online at eaton.com/filtration for a complete list of Eaton's filtration products.



